



ලංකා බන්ධන තෙල් නීතිගත සංස්ථාව 1/3
(වර්ෂ 1961 අංක 28 දරණ පාර්ලිමේන්තු පනතින් ස්ථාපිත කරන ලදී.)
පිරිපහදු කායසාංගය, තැ.පෙ. 11, කැලණිය.

இலங்கை பெற்றோலியக் கூட்டுத்தாபனம்
(1961ம் ஆண்டின் 28ம் இலக்க பாலாளுமன்ற
சட்டத்தின்படி அமைக்கப்பட்டது)
எண்ணெய் சுத்திகரிப்புப் பிரிவு
த. பெ. இலக்கம் 11, களணிய.

THE CEYLON PETROLEUM CORPORATION)
(Established by Act of Parliament No. 28 of 1961)
Refinery Division, P.O. Box 11, Kelaniya.
Tel : 2400110, 2400427-29 Fax : 2400102, 2400436
E-mail : ref.materials@ceypetco.gov.lk
refmaterials@slt.net.lk

REQUEST FOR QUOTATION

Our Ref:GL1 - LG19-089 -
Date:28.08.2019

Please quote Price for DELIVERY AT REFINERY, SAPUGASKANDA and submit your sealed quotation marked with our reference & closing date on the left hand top corner. Furnish samples/ catalogues/ information as requested below. Your quotations should reach us ON OR BEFORE 19. 09. 2019 - 2.30 PM.. ANY DEVIATIONS SHOULD BE INDICATED CLEARLY.

Quotations received after closing date are liable to be rejected. Payment will be made within 30 DAYS of delivery. Please indicate VAT registration No. and amount separately if applicable. Your offer should be valid for 25.11. 2019 from closing date. Country of origin & delivery date to be mentioned against each item. Please comply with our general conditions & instructions given IN THIS WEB - SECTION.

Thanking You,
Yours Faithfully,


.....
Manager (Materials) / Deputy Manager (Planning)

(To be completed by supplier)

Item No	Qty	Unit	Description	Unit Price	Amount (Without VAT)
001	3	EA	A MEDIUM VOLTAGE, INDOOR WOUND TYPE DOUBLE CORE CURRENT TRANSFORMER AS PER ATTACHED SPECIFICATIONS.		
			Total Without Tax	----	
			(if any) ...%NBT----		
			(if any) ...%VAT----		
			Total Amount with NBT+VAT----		

UNSIGN BIDS WILL BE REJECTED

To: Ceylon Petroleum Corpn.

We submit the foregoing quotations on the terms and conditions mentioned above.

REQUEST FOR QUOTATION

(Contd.)

Our Ref:GL1 - LG19-089 - 1100131894

Item No	Qty	Unit	Description	Unit price (Without VAT)	Amount
---------	-----	------	-------------	-----------------------------	--------

The quotation remains open for acceptance either wholly or in part by you. Our offer is valid till

Our Tel./Fax.....
VAT No.....

Signed.....
Company Stamp

**SPECIFICATION FOR A MEDIUM VOLTAGE, INDOOR WOUND TYPE,
DOUBLE CORE CURRENT TRANSFORMER**

1. PRIMARY SYSTEM VOLTAGE : 3300 V, 50 Hz Line to Line
2. RATED PRIMARY CURRENT : 100 A
3. RATED SECONDARY CURRENT :
CT 1 : 5 A
CT 2 : 5 A
4. SERVICE :
CT 1 : For metering
CT 2 : For operation of protection relays
5. BURDEN :
CT 1 : 40 VA
CT 2 : 25 VA
6. ACCURACY :
CT 1 : Class 1.0, $n < 10$
CT 2 : 5 P 10, $n > 10$
7. SHORT CIRCUIT CAPACITY : 25 kA
8. CONSTRUCTION : Mould plastic casing. Indoor type
9. MOUNTING : Horizontal mounting inside a switchgear panel.
10. AMBIENT TEMPERATURE : 20°C to 40°C
11. RELATIVE HUMIDITY : 5% to 95%, non-condensing
12. STANDARDS :
Current Transformers should be Designed, Manufactured and Tested in accordance with the IEC standards, latest editions.
13. LITERATURE :
Make / Model / Country of origin / Specifications / Dimensional drawing / Bus bar size / Mounting details shall be provided along with the offer. All literature shall be in English.
14. WARRANTY :
Current Transformers shall have a warranty for at least one year.

LG19-089.

J