



ලංකා බහිෂ් තෙල් නීතිගත සංස්ථාව
(වර්ෂ 1961 අංක 28 දරණ පාර්ලිමේන්තු පනතින් ස්ථාපිත කරන ලදී.)
පිරිපහදු කායසීමා, ත.පෙ. 11, කැලණිය.

1/5

இலங்கை பெற்றோலியக் கூட்டுத்தாபனம்
(1961ம் ஆண்டின் 28ம் இலக்க பாலாளுமன்ற
சட்டத்தின்படி அமைக்கப்பட்டது)
எண்ணெய் சுத்திகரிப்புப் பிரிவு
த. பெ. இலக்கம் 11. களணிய.

THE CEYLON PETROLEUM CORPORATION
(Established by Act of Parliament No. 28 of 1961)
Refinery Division, P.O. Box 11, Kelaniya.
Tel : 2400110, 2400427-29 Fax : 2400102, 2400436
E-mail : ref.materials@ceypetco.gov.lk
refmaterials@sltnet.lk

REQUEST FOR QUOTATION

Our Ref:GL1 - SR18-114
Date:31.10.2018
Contact Person:

Please quote Price for DELIVERY AT Refinery, Sapugaskanda and submit your sealed quotation marked with our reference & closing date on the left hand top corner. Furnish samples/ catalogues/ information as requested below. Your quotations should reach us On or before 29-11-2018 at 1400 hrs.. ANY DEVIATIONS SHOULD BE INDICATED CLEARLY.

Quotations received after closing date are liable to be rejected. Payment will be made within 30 days of delivery. Please indicate VAT registration No. and amount separately if applicable. Your offer should be valid for 60 days from closing date. Country of origin & delivery date to be mentioned against each item. Please comply with our general conditions & instructions given

Thanking You,
Yours Faithfully,

.....
Manager (Materials)/Depty. Manager (Planning)

(To be completed by supplier)

Item No	Qty	Unit	Description	Unit Price	Amount (Without VAT)
001	1	EA	UN-INTERRUPTIBLE POWER SUPPLY SYSTEM To supply, install, test and commissioning of an UPS system <u>As per the attached specificatin sheets</u>		
Total Without Tax				----	
(if any) ...%NBT----					
(if any) ...%VAT----					
Total Amount with NBT+VAT----					

UNSIGNIED BIDS WILL BE REJECTED

To: Ceylon Petroleum Corpn.

2/5

REQUEST FOR QUOTATION

(Contd.)

Our Ref:GL1 - SR18-114

Item No	Qty	Unit	Description	Unit price (Without VAT)	Amount
---------	-----	------	-------------	-----------------------------	--------

We submit the foregoing quotations on the terms and conditions mentioned above. The quotation remains open for acceptance either wholly or in part by you. Our offer is valid till

Our Tel./Fax.....
VAT No.....

Signed.....
Company Stamp

Un-interruptible power supply System for Finance Department

1. Scope :

To supply, install, test and commissioning of an UPS system comprising of 01 Nos of 8 KVA / 6 KW on line UPS unit with external battery bank at Ceylon Petroleum Corporation, Refinery.

2. System Configuration:

Proposed UPS system shall have following features

- (i) UPS module shall be industrial type with the capability of providing specified continuous output power of 8 KVA / 6 KW.
- (ii) UPS module shall be operated on – line.
- (iii) Features to display on a LCD panel status indication for event logger, alarm and tripping conditions, self diagnostic features etc.
- (iv) UPS shall be facilitated with external alarm outputs (Analog/Digital).
- (v) UPS shall be facilitated with battery monitoring system with temperature compensation of battery voltage.

3. Specifications :

(i) Input

Voltage : 230 V AC, single phase +/- 10% variation
Frequency : 50 Hz +/- 5% variation

(ii) Output

Voltage : 230 V AC, single phase within +/- 2%
Frequency : 50 Hz within +/- 0.5% variation
Rating : 8 KVA / 6 KW continuous
Waveform : True sine wave

(iii) Battery

Type : Lead Acid or Lead calcium sealed/ maintenance free
Autonomy Time : More than 30 minutes with 100% of rated load.
Battery Life : Shall have a minimum of 3 years guaranteed life

J

4. Ambient Conditions:

Temperature : 40° C
Relative Humidity : 90% (non condensing)
Altitude above sea level : Less than 1000 m

5. Other Requirements:

Standard : IEC EN62040, BS 6290, IEC 60146 IEC 60950 or equivalent internationally recognized standard (please specify).
Noise Level : less than 50 dB(A).
EMC Conformity : IEC 62040-2 EMC Directive2004/108/CE.
Harmonic Distortion : THD Less than 5% (For non -linear loads).
Spares : A separate price list for spares required for a period of 5 years. operation shall be provided along with the main offer.
Design : UPS shall not be a prototype.

6. Manuals :

Operating and maintenance instruction manuals containing following information and in English language shall be provided in duplicate along with the equipment.

- (i) The trouble shooting procedures
- (ii) Relevant circuit diagrams

Note: Relevant technical details/catalogues of the UPS shall be produced along with the main offer for evaluation purposes.

7. Warranty:

- (i) Supplier shall provide comprehensive warranty for all equipment including batteries for a minimum period of 3 years from the date of commissioning.
- (ii) Supplier shall have all spare parts necessary to carry out maintenance during the warranty period and thereafter upon agreement between the two parties concerned.

8. Installation, Testing and commissioning:

Supplier shall be responsible for installation, testing and commissioning of the equipment supplied. A separate quotation for installation, testing and commissioning shall be submitted with the main offer.

5/5

9. Workshop Facilities

1. The supplier should have a well established workshop and trained technical staff to carry out maintenance and servicing the offered UPS system.
2. The supplier shall enter into a service agreement for the offered UPS system if CPC wishers to do so. Warranty condition is independent from the service agreement.

10. General conditions

1. The offered model and brand shall be a well established brand in Sri lanka. The offered UPS system shall be manufactured in a European, American or Japanese manufacturing facility.
2. The offered UPS system shall be well protected against lightning surges, overload conditions, short circuit conditions, external power quality disturbances etc.. and features clearly indicated in the offer.
3. The UPS manufacture shall have a ISO 9000 certification. If the bidder is not the manufacturer for the UPS system, a letter of authorization from the manufacturer to the bidder should be provided.
4. A site reference list for the offered UPS system operating in sri lanka shall be provided.

J