



CEYLON PETROLEUM CORPORATION

Project Title:

CONSTRUCTION OF A JET A-1 TRANSFER PIPELINE FROM MUTHURAJAWELA TO BIA KATUNAYAKE AND CONSTRUCTION OF JET A-1 STORAGE TANKS AND ASSOCIATED FACILITIES WITH MODIFICATIONS TO THE EXISTING TERMINAL FACILITY AT MUTHURAJAWELA

Document Title:

Epoxy Coating on Internal Surface of Piping

Project Owner: CEYLON PETROLEUM CORPORATION (CPC)

Document No: 7258-1872/2

- Internal Coating method - Plant applied approved Epoxy coating for Jet A-1
- Application standard - EI 1541 (Requirements for internal protective coating systems used in aviation fuel handling systems.)
- Minimum layers thickness - 150 microns DFT (internal coating)
- Expected life duration of coating - 30 years