

ADDENDUM - 01

Bid for the Supply of Fittings & Consumable for Trincomalee Tank Farm

B/25/2026

Bidders are hereby informed that the technical specifications for the following items have been revised. The revised specifications shall supersede the corresponding descriptions given in the original Bidding Document.

Elbows					
Item No.	Qty.	Unit	Size	Previous Description	New Description
01	56	Nos.	20"	ELL 90 LR, BW, ASME B16.9, ASTM A234 GR WPB SMLS, SCH 40	BEND 90, 5D, BW, MSS SP-75, ASTM A234 GR WPB SMLS, SCH 40
02	195	Nos.	20"	ELL 45 LR, BW, ASME B16.9, ASTM A234 GR WPB SMLS, SCH 40	BEND 45, 5D, BW, MSS SP-75, ASTM A234 GR WPB SMLS, SCH 40

The above revised specifications shall be read together with and shall form an integral part of the Bidding Document.

All other terms and conditions of the Bidding Document remain unchanged.

Chairman,
Department Procurement Committee,
c/o Manager (Procurement & Stores),
Ceylon Petroleum Corporation,
No. 609, Dr. Danister De Silva Mawatha,
Colombo 09,
Sri Lanka.

Tele : 0094-11-7296336

E-mail : procuregeneral@ceypetco.gov.lk