



Clarification 2

B/25/2026 - FITTINGS & CONSUMABLE FOR TRINCOMALEE TANK FARM DEVELOPMENT

Date - 2026/05/12

Item	Reference	Quarry	Answer by CPC
1	Section 3. TECHNICAL SPECIFICATIONS Item No.45-53	<ul style="list-style-type: none">• Diameter of the Bolt Could be identified from flange Size though. But Length of Each Bolt is depend on sight condition and Customer requirement and preference. Therefore we kindly request for your clarification on; Diameter of Bolt and Length of Each Bolt	<ul style="list-style-type: none">• Nut & Bolt Size and Length should be according to the ASME B16.5.• Length should be obtain from ASME B16.5-Clause 6.10.2.
2	Section 3. TECHNICAL SPECIFICATIONS Item No.45-53	<ul style="list-style-type: none">• Is there any additional requirement for Flat Washers or Spring Washer.	<ul style="list-style-type: none">• No