



**CEYLON PETROLEUM CORPORATION**

ENGINEERING DEPARTMENT,  
509, Dr. DENISTER DE SILVA MAWATHA  
COLOMBO - 09  
T.P. NO: 0115455455, 0115661616  
FAX NO: 0115-455-406

**PROJECT:**  
FABRICATION OF 3000 IG TANKS

**TITLE:**  
FABRICATION DETAILS OF  
3000 IG FUEL STORAGE TANK

**DRAWING NO:** CEYPET / ENQ / UG32017

**SCALE:** Not to scale      **DATE:** 31.05.2017

**DRAWN BY:**

**CHECKED BY:**

**APPROVED BY:**

REV.	DESCRIPTION	DATE

**NOTE**

- (1) TANK TO BE FABRICATED WITH STEEL MENTIONED IN THE SPECIFICATIONS GIVEN IN TENDER DOCUMENT.
- (2) TANK TO BE SUPPLIED WITH MANHOLE COVER FITTINGS ASBESTOS RING AND BOLTS & NUTS AS SHOWN ON DRAWING.
- (3) TANK TO BE AIR PRESSURE TESTED TO 8 PSI FOR 2 HOURS IN THE FACTORY/WORKSHOP AT THE PRESENCE OF C.P.C. ENGINEER.
- (4) DIP ROD TO BE GRADED IN CENTIMETRES WITH SUB DIVISIONS IN 2.5 MILLIMETRES INCLUDING BOTTOM END BRASS FERRULE & 12 MM GAP.
- (5) UNLESS SPECIFIED, ALL DIMENSIONS ARE IN MILLIMETRES.

