



CEYLON PETROLEUM CORPORATION

ENGINEERING DEPARTMENT,
309, Dr. DENISTER DE SILVA MAWATHA
COLOMBO 09,
T.P.NO: 9115455455, 9115661919
FAX NO: 9115435408

PROJECT:
FABRICATION OF 5000 IG TANKS

TITLE:
FABRICATION DETAILS OF
5000 IG FUEL STORAGE TANK

DRAWING NO: CEYPET/ENG/UG52017

SCALE: Not to scale **DATE:** 31.05.2017

DRAWN BY:

CHECKED BY:

APPROVED BY:

REV.	DESCRIPTION	DATE

- NOTE**
- TANK TO BE FABRICATED WITH STEEL MENTIONED IN THE SPECIFICATIONS GIVEN IN TENDER DOCUMENT.
 - TANK TO BE SUPPLIED WITH MANHOLE COVER FITTINGS ASBESTOS RING AND BOLTS & NUTS AS SHOWN ON DRAWING.
 - TANK TO BE AIR PRESSURE TESTED TO 3.75I FOR 2 HOURS IN THE FACTORY/WORKSHOP AT THE PRESENCE OF C.P.C. ENGINEER.
 - DIP ROD TO BE GRADED IN CENTIMETRES WITH JUB DIVISIONS IN 1.5 MILLIMETRES (INCLUDING BOTTOM END BRASS FERRULE & 12 MM GAP.
 - UNLESS SPECIFIED, ALL DIMENSIONS ARE IN MILLIMETRES.

