



ලංකා බහිෂ තෙල් නීතිගත සංස්ථාව

(වර්ෂ 1961 අංක 28 දරණ පාර්ලිමේන්තු පනතින් ස්ථාපිත කරන ලදී.)

පිරිපහදු කායකීංශය, ත.පෙ. 11, කැලණිය.

இலங்கை பெற்றோலியக் கூட்டுத்தாபனம்

(1961ம் ஆண்டின் 28ம் இலக்க பாலாளுமன்ற

சட்டத்தின்படி அமைக்கப்பட்டது)

எண்ணெய் சுத்திகரிப்புப் பிரிவு

த. பெ. இலக்கம் 11, களணிய.

THE CEYLON PETROLEUM CORPORATION

(Established by Act of Parliament No. 28 of 1961)

Refinery Division, P.O. Box 11, Kelaniya.

Tel : 2400110, 2400427-29 Fax : 2400102, 2400436

Email : ref.materials@ceypetco.gov.lk

refmaterials@slt.net.lk

REQUEST FOR QUOTATION

Our Ref:GL1 - 23-0044 P -

Date:20.01.2023

Contact Person:

Please quote Price for DELIVERY AT REFINERY, SAPUGASKANDA and submit your sealed quotation marked with our reference & closing date on the left hand top corner. Furnish samples/ catalogues/ information as requested below. Your quotations should reach us ON OR BEFORE 09..02.2023 2.30 P.M.. ANY DEVIATIONS SHOULD BE INDICATED CLEARLY.

Quotations received after closing date are liable to be rejected. Payment will be made within 30 DAYS of delivery. Please indicate VAT registration No. and amount separately if applicable. Your offer should be valid for 30 DAYS from closing date. Country of origin & delivery date to be mentioned against each item. Please comply with our general conditions & instructions given .

QUOTATIONS WITHOUT DELIVERY DATE MAY BE REJECTED

Thanking You,
Yours Faithfully,


Manager (Materials)/Depty. Manager (Planning)

(To be completed by supplier)

Item No	Qty	Unit	Description	Unit Price	Amount (Without VAT)
---------	-----	------	-------------	------------	-------------------------

001	1	EA			
-----	---	----	--	--	--

STEEL ENCLOSURE

(AS PER ATTACHED SPECIFICATIONS

SHEET)

Total Without Tax -----

(if any) ...%VAT-----

Total Amount with VAT-----

KINDLY ACKNOWLEDGE THE RECEIPT OF OUR

Specifications for Control Centre Enclosure

1. Scope

To fabricate and supply 01 no of control centre Enclosure as per given CPC drawing no. 7258 - B

2. Service Condition

Environment	: Indoor
Humidity	: 95% non condensing
Atmosphere	: Corrosive and Dusty
Location	: Petroleum Refinery

3. Expected Features

Enclosure Dimensions : As per drawing CPC drawing no . 7258 - B

Plate Thickness : 1.5 mm

Mounting : Free Standing

Finish : Epoxy powder coated

Color : Industrial Gray

Door & Lock : Doors marked as A & B to be supported by hinges and opened on to a sideway with a quarter turn lock operated by common panel key.

Doors marked as C & D to be installed by nuts and bolts. Also shall be removable easily .

Door gasket : Should be of oil resistant make.

Internal mounting plate : Required.


Handling : Removable lifting bolts shall be provided.

Cable Entry : From the bottom of the panel.


4. General Conditions

- Printed product catalogues, Dimensional drawings and technical details in English language are to be provided along with the offer.
- It is the total responsibility of the bidder to inspect the similar enclosure at Refinery Sapugaskanda before quoting.









END ELEVATION



FRONT ELEVATION



DOOR TYPES

REFERENCE DRAWINGS

LAYOUT OF BOILER CONTROL PANELS CPC 7258 A

B						
A						FOR CONSTRUCTION
O	31.12.22	NALINDA				FOR COMMENTS
REV	DATE	BY	CHK.	APPROVED	DESCRIPTION	

UTILITY CONTROL DESK

LOCATION :- UTILITIES

PROJ.No:- 1502

CEYLON PETROLEUM CORPORATION,
REFINERY DIVISION,
SAPUGASKANDA.

SCALE:-

DWG.No:-7258-B